

Date/Time	CAD#	Incident Type Group	Incident Type	Heat Source Name	Fire Cause Name
7/05/2018	F2539144	Structure Fire	Structure fire with damage	Short circuit arc: Defective or worn insulation	Short circuit, earth fault
15/03/2018	F2502868	Structure Fire	Structure fire with damage	Heat from electrical equip: Defective or faulty	Operating deficiency - not classified above
2/12/2017	F2429963	Structure Fire	Structure fire with no damage	Arc from switch, electric fence or operating equip	Mechanical failure, malfunction - Other
29/11/2017	F2428251	Structure Fire	Structure fire with no damage	Short circuit arc: Water cause	Mechanical failure, malfunction - Other
10/08/2017	F2359998	Structure Fire	Structure fire with damage	Heat from electrical equip: Defective or faulty	Other electrical failure
13/11/2016	F2186479	Structure Fire	Structure fire with damage	Short circuit arc: Water cause	Other electrical failure
9/10/2016	F2165229	Structure Fire	Structure fire with damage	Short circuit arc: Unspecified	Undetermined
16/09/2016	F2152565	Structure Fire	Structure fire with no damage	Short circuit arc: Water cause	Undetermined
28/07/2016	F2122541	Structure Fire	Structure fire with damage	Heat from electrical equip: Defective or faulty	Installation deficiency
14/07/2016	F2114514	Structure Fire	Structure fire with no damage	Heat from electrical equip: Defective or faulty	Other electrical failure
19/06/2016	F2099807	Structure Fire	Structure fire with damage	Heat from electrical equip: Defective or faulty	Short circuit, earth fault
21/11/2015	F1962549	Structure Fire	Structure fire with damage	Short circuit arc: Water cause	Short circuit, earth fault
13/08/2015	F1898966	Structure Fire	Structure fire with no damage	Heat from electrical equip: Defective or faulty	Short circuit, earth fault